



Wicklow County Council
COMHAIRLE CHONTAE CHILL MHANTAIN

Access Audit Summary Sheet

CAPITA SYMONDS

Subject: **Greystones Town Centre**

Audited: **25 March 2008**

Details: **Co. Wicklow**

Accessibility Grade

A - Wholly Compliant

B- Satisfactory, minor works needed

C - Poor. Major alterations required

D - Significant issues which severely restrict access and service operations. Major capital works required

Allocated Grading

B

Estimate of Totals	No of Alterations	Estimated Costs
Priority 1	36	€103,850
Priority 2	46	€82,950
Priority 3	10	€48,600
Priority 4	13	€29,850
All Costs	105	€265,250

<i>Auditor:</i>	K Craig
<i>Signed:</i>	
<i>Date:</i>	

Summary Statement

Greystones is a busy, medium sized town, with a number of amenities throughout its town centre, including a new shopping centre. The access audit was carried out by Ken Craig and is based on the conditions encountered during an inspection on the 31st March 2008.

The survey included the area from the Council Offices located on Mill Street, through the centre of the town to Victoria Road and then towards the seafront, including the adjacent roads. Please refer to the Greystones Outskirts report for comments of the remaining area of the town. The area audited within this report can be clearly identified on the map overleaf.

The audit looked at crossing points, tactile paving, general circulation, obstructions and car parking. The town is fairly accessible throughout, but alterations are required to ensure barrier free access. The main issues identified during the access audit include the following:

- Condition and obstructions on pavements, including necessary widening works and ensuring that pavements do not have excessive cross-falls.
- Upgrading and formation of new road crossovers.
- Providing a suitable provision for wheelchair accessible car parking.
- Suitable provision of temporary footpath at new harbour development.

Please refer to section 4 for full audit findings.