



## Greystones - Delgany & Kilcoole Draft LPF Amendment Stage Submission - Report

Who are you:	State Body
Name:	Uisce Éireann
Reference:	GDKLPF-155914
Submission Made	November 20, 2025 4:50 PM

---

## File

25\_UE\_FP\_49 GRYST\_LFP-MAs.pdf, 0.17MB

Planning Department,  
Wicklow County Council  
County Buildings  
Station Road,  
Wicklow Town,  
A67 FW96

Submission via Consultation Portal

[25\_UE\_FP 49-GRYST-LFP\_MAs]

20<sup>th</sup> November 2025

**Re: Variation No. 4 to the Wicklow County Development Plan  
Greystones, Delgany & Kilcoole Local Framework Plan – Material Alterations**

**Uisce Éireann**  
Teach Colvill  
24-26 Sráid Thalbóid  
Baile Átha Cliath 1  
D01 NP86  
Éire

**Uisce Éireann**  
Colvill House  
24-26 Talbot Street  
Dublin 1  
D01 NP86  
Ireland

**T:** +353 1 89 25000  
**F:** +353 1 89 25001  
**[www.water.ie](http://www.water.ie)**

A Chara,

Uisce Éireann (UÉ), welcomed the notification of the consultation process for the Material Alterations to the Draft Framework Plan.

We have no objections to the proposed changes in land zoning. We would like to mention

- 1) The GDA water supply RAG status remains Amber.
- 2) Watermain upgrades may be required in some areas, particularly where the adjacent mains are of small diameter. If there is no UE project in the area, upgrades shall be developer funded.
- 3) Sewer and / or pumping station upgrades may be required in some areas. Where there is no UE project, these shall be developer funded.

If you require any further information or assistance in respect of this submission or in respect of the availability of capacity in our infrastructure to support the plan making process, please do not hesitate to contact us.

Yours faithfully,

*Niamh McDonald*

---

**Niamh McDonald**  
Asset Strategy  
Forward Planning - East and Midlands Region